



PLAN VIEW

SECTIONAL ELEVATION

SECTION A-A

**SPECIFICATIONS**

- 1. MANUFACTURE IN ACCORDANCE WITH ZS3109:1987 (PRECAST UNITS).
- 2. SURFACE FINISHES TO NZS 3114:1987, FORMED SURFACES - F4 TROWELLED SURFACES - U2
- 3. CONCRETE STRENGTH : a. f'c = 40MPa b. STRIPPING STRENGTH (Min) = 15MPa .
- 4. DESIGN LOAD IS 0.85 HN
- 5. Q in = 13 m<sup>3</sup>/hr.

550 x 200 HOLE IN BOTTOM OF BAFFLE



**Humes Pipeline Systems**  
 Private Bag 92817  
 Auckland  
 Freephone 0800 502 112  
 www.humes.co.nz

Copyright This design, information and drawing remain the property of Humes Pipeline Systems and may not be used or copied without approval in writing from Humes Pipeline Systems.

**2200 LITRE OIL & GRIT INTERCEPTOR**

Revision	Rev. Date	Changes Made

Drawn By	LA	Date	12/12/03
Checked By		Scale	A4 DO NOT SCALE
Reference No.			
Drawing No.			
Rev. No.	0		