



**NOTES:**

- 1 MANUFACTURE IN ACCORDANCE WITH NZS 3109:1997 ( PRECAST UNITS)
- 2 CONCRETE STRENGTH @ 28 DAYS 40MPa, MIN. STRIPPING STRENGTH 15MPa
- 3 REINFORCEMENT STEEL IN ACCORDANCE WITH NZS 3422 & NZS 3402 HD BARS = 430MPa & MESH = 485MPa
- 4 SURFACE FINISHES TO NZS 3114:1987, FORMED SURFACE - F4 FINISH & TROWELLED SURFACE - U2 FINISH
- 5 ALL JOINTS TO BE EPOXIED
- 6 FOR LIFTING OF COMPLETE UNIT (EXCLUDING LID) A FOUR POINT EQUALISED SYSTEM USING THE 5T FA120 ANCHORS ONLY SHOULD BE USED

<p><b>Humes Pipeline Systems</b> Private Bag 92817 Auckland Freephone 0800 502 112 www.humes.co.nz</p>		Contractor		HUMES	
		PHONE		WWW.	
Rev	Description	Date	By	Chkd	Product
A	FOR APPROVAL FOR CONSTRUCTION	11-08-08	GB	-	INSPEC. CHAMBER
B		01-02-09	GB	-	Layout On SHEET NO.
<p>Dwg Title: ELEVATIONS</p> <p>Project Name: TELCO 2050x1225x800 HIGH FOOTWAY CHAMBER</p> <p>Product Code: 04818</p> <p>Scale: NTS</p> <p>Drawn: GB</p> <p>Checked By: WA</p> <p>Dwg. No.: 04818-S1</p> <p>Rev.: B</p>					

Copyright: The design, information and drawing remain the property of Humes Pipeline Systems and may not be used or copied without approval in writing from Humes Pipeline Systems.